



SAFETY ALERT

Surge Protector Notification

RISK MANAGEMENT & SAFETY

Date: September 2015
Category: Electrical hazard, risk of fire
RMS Contact: Kirk Flickinger, kflickin@nd.edu

Contact RMS:

Tel: 1-5037

A local municipality recently tested an emergency generator for one of their facilities. During that test it was discovered that multiple surge protectors of the same make and model overheated causing a risk of fire. Please inspect any surge protectors in your work area. If you discover a Belkin, Surge Master product like the one pictured below please purchase a replacement surge protector. Please contact Risk Management and Safety for removal and proper disposal of any surge protectors taken out of service as a result of this alert.



Document #: 15-0034