

NFPA 70E Table 130.4(D)(b)

Shock Protection Boundaries to Exposed Energized Electrical Conductors or Circuit Parts for Direct-Current Voltage Systems

Nominal Potential Difference	Limited Approach Boundary	Restricted Approach Boundary
Less than 50 V	Not specified	Not specified
50 V - 300 V	3 feet, 6 inches	Avoid Contact
301 V - 1 kV	3 feet, 6 inches	1 foot
<i>Over 1 kV or a movable conductor (a condition in which the distance between the conductor and a person is not under the control of the person)</i>		
<i>See NFPA 70 E Table 130.4 (D)(b)</i>		